

Er. Ramavtar Verma

AMIE (AM181763-1)

Hsyp REGD NO-183

SHOP NO 111, MAHALUXMI MARKET

DABRA CHOWK, HISAR (HARYANA)

Ph.No.9991432897

Email:- ramverma53@gmail.com

RFE- JPS/ST/06/2025-26

DATE:--- 10-05-2025

Structure Stability Certificate

Certified that the Building of Royal Public School. Village Bahbal Pur, Fatehabad 125050. Haryana to check the structural stability of the Building.

I have personally inspected the site & observations are as follow :-

1. The load of the roof's is on the walls. Walls are sufficient to take the load.
2. Building is fully ventilated and lighted and structurally stable.
3. The building is constructed as per the IS code 456 -2000 of specification and standards.
4. Brick masonry walls are in good condition and floors and roofs are also in good condition.
5. The certificate is valid for one year from date of issue

In view of the above observations it is reported that the floor of the Building is safe for working.

Er. Ramavtar Verma

Er. Ramavtar Verma
(Structure/Chartered Engg.
131-P, Lajpat Nagar, Near
Lazeez Hotel, Hisar
Regd. in HUDA, M.C
AMIE (AM181763-1)
9991432897